



CSA INTERNATIONAL

# Certificate of Compliance

Certificate: 1795430

Master Contract: 202993

Project: 1795430

Date Issued: 2006/07/25

Issued to: International Metal Engineering

Blk 13 Toa Payoh Lorong 8 06-05  
Braddell Tech Park  
Singapore, 319261  
Singapore  
Attention: Mr. Mohan Dutt

*The products listed below are eligible to bear the CSA Mark shown*



Issued by:

  
Ezio Migliozi

Authorized by: Patricia Pasemko, Operations  
Manager



## PRODUCTS

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III; Type 4X; T6

Digital Temperature Indicators with or without battery operated, Models 8080KN and 8088PR, 28 Vdc max.;  
conduit entry sizes: 1/2" NPT or 3/4" NPT.

## APPLICABLE REQUIREMENTS