



Certificate of Compliance

Certificate: 1795370

Master Contract: 202993

Project: 1795370

Date Issued: 2006/08/17

Issued to: **International Metal Engineering**
Blk 13 Toa Payoh Lorong 8 06-05
Braddell Tech Park
Singapore, 319261
Singapore
Attention: Mr. Mohan Dutt

The products listed below are eligible to bear the CSA Mark shown



Issued by:


Ezio Migliozi

Authorized by: Patricia Pasemko, Operations
Manager



PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III; Type 4X; T6

Digital Temperature Transmitter, Model 8080PN, 24 Vdc, 70 mA; conduit entry sizes: ½" NPT or ¾" NPT

APPLICABLE REQUIREMENTS

-CSA Std C22.2 No 0.4-04 - Bonding of Electrical Equipment

-CSA Std C22.2 No. 0.5-M1982 - Threaded Conduit Entries